

Energy performance certificate (EPC)

16, George Street
LEOMINSTER
HR6 8JZ

Energy rating

E

Valid until: 15 July 2025

Certificate number: 0933-2853-7148-9425-5835

| | |
|------------------|---------------------|
| Property type | Semi-detached house |
| Total floor area | 68 square metres |

Rules on letting this property

Properties can be let if they have an energy rating from A to E.

You can read [guidance for landlords on the regulations and exemptions \(https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance\)](https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance).

Energy rating and score

This property's energy rating is E. It has the potential to be B.

[See how to improve this property's energy efficiency.](#)

The graph shows this property's current and potential energy rating.

Properties get a rating from A (best) to G (worst) and a score. The better the rating and score, the lower your energy bills are likely to be.

For properties in England and Wales:

the average energy rating is D
the average energy score is 60

| Score | Energy rating | Current | Potential |
|-------|---------------|---------|-----------|
| 92+ | A | | |
| 81-91 | B | | 81 B |
| 69-80 | C | | |
| 55-68 | D | | |
| 39-54 | E | 44 E | |
| 21-38 | F | | |
| 1-20 | G | | |

Breakdown of property's energy performance

Features in this property

Features get a rating from very good to very poor, based on how energy efficient they are. Ratings are not based on how well features work or their condition.

Assumed ratings are based on the property's age and type. They are used for features the assessor could not inspect.

| Feature | Description | Rating |
|----------------------|--|-----------|
| Wall | System built, as built, no insulation (assumed) | Very poor |
| Wall | Timber frame, as built, partial insulation (assumed) | Average |
| Roof | Pitched, 150 mm loft insulation | Good |
| Window | Fully double glazed | Good |
| Main heating | Electric storage heaters | Average |
| Main heating control | Manual charge control | Poor |
| Hot water | Electric immersion, off-peak | Very poor |
| Lighting | Low energy lighting in 38% of fixed outlets | Average |
| Floor | Solid, no insulation (assumed) | N/A |
| Secondary heating | Room heaters, mains gas | N/A |

Primary energy use

The primary energy use for this property per year is 597 kilowatt hours per square metre (kWh/m²).

Additional information

Additional information about this property:

- System build present
-

How this affects your energy bills

An average household would need to spend **£1,216 per year on heating, hot water and lighting** in this property. These costs usually make up the majority of your energy bills.

You could **save £569 per year** if you complete the suggested steps for improving this property's energy rating.

This is **based on average costs in 2015** when this EPC was created. People living at the property may use different amounts of energy for heating, hot water and lighting.

Heating this property

Estimated energy needed in this property is:

- 11,271 kWh per year for heating
- 2,022 kWh per year for hot water

Impact on the environment

This property's environmental impact rating is F. It has the potential to be C.

Properties get a rating from A (best) to G (worst) on how much carbon dioxide (CO₂) they produce each year.

Carbon emissions

An average household produces 6 tonnes of CO₂

This property produces 6.9 tonnes of CO₂

This property's potential production 1.7 tonnes of CO₂

You could improve this property's CO₂ emissions by making the suggested changes. This will help to protect the environment.

These ratings are based on assumptions about average occupancy and energy use. People living at the property may use different amounts of energy.

Changes you could make

| Step | Typical installation cost | Typical yearly saving |
|--|---------------------------|-----------------------|
| 1. Floor insulation (solid floor) | £4,000 - £6,000 | £55 |
| 2. Add additional 80 mm jacket to hot water cylinder | £15 - £30 | £23 |
| 3. Low energy lighting | £25 | £25 |
| 4. Gas condensing boiler | £3,000 - £7,000 | £425 |
| 5. Solar water heating | £4,000 - £6,000 | £42 |

| Step | Typical installation cost | Typical yearly saving |
|------------------------------|---------------------------|-----------------------|
| 6. Solar photovoltaic panels | £5,000 - £8,000 | £276 |

Help paying for energy improvements

You might be able to get a grant from the [Boiler Upgrade Scheme \(https://www.gov.uk/apply-boiler-upgrade-scheme\)](https://www.gov.uk/apply-boiler-upgrade-scheme). This will help you buy a more efficient, low carbon heating system for this property.

More ways to save energy

Find ways to save energy in your home by visiting www.gov.uk/improve-energy-efficiency

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

| | |
|-----------------|--|
| Assessor's name | Richard Horlock |
| Telephone | 01568 610600 |
| Email | r.horlock@btinternet.com |

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

| | |
|----------------------|--|
| Accreditation scheme | NHER |
| Assessor's ID | SAVA001252 |
| Telephone | 01455 883 250 |
| Email | enquiries@elmhurstenergy.co.uk |

About this assessment

| | |
|------------------------|--|
| Assessor's declaration | Employed by the professional dealing with the property transaction |
| Date of assessment | 27 April 2015 |
| Date of certificate | 16 July 2015 |
| Type of assessment | RdSAP |